



QUESTION: Is it possible to locate the HVAC unit to the top roof of the building? Also, how will unit be attached to building (what kind of hardware and will it cause damage to masonry?)

ANSWER:

- Unit will have to be wall-mounted with 4-6 tapcon screws for wall bracket on the not-visible side of the building that faces the alley and is obscured by a lower roof line.
- Also unit on wall in case they have future roof replacement.
- Also tapcon screws are 1 1/2 inch in length will not damage brick.
- Also tapcon screws are no greater than 3/8 inch in diameter.

QUESTION: Please submit product information of the proposed unit showing dimensions and colors.

ANSWER:



Mitsubishi - 20k BTU - M-Series Outdoor Condenser - For 2 Zone

Product Height

27 5/16 Inches

Product Width

33 1/16 Inches

Product Depth

13 Inches

Product Weight

126 Pounds

External Finish Color Munsell 3.0Y 7.8/1.1