



WEIR OPENING
DETAIL

NOTES:

1. PROVIDE 4" BREAKS IN CURB REVEAL AT 6'-0" O.C. TO ALLOW SIDEWALK RUNOFF INTO BIORETENTION AREAS (UNLESS NOTED OTHERWISE ON THE PLANS).
2. UPSTREAM OF WEIRS, BREAKS IN CURB REVEAL SHALL BE LOCATED A MIN. OF 1" ABOVE THE WEIR OPENING TO LIMIT THE POTENTIAL FOR THE BIORETENTION AREA TO OVER-TOP ONTO THE SIDEWALK.
3. IF USED IN CONTINUOUS SWALE, ALL WEIRS SHALL BE CONSTRUCTED OF THE SAME MATERIAL.



**Public Works Department
Engineering Division**

1 CITY HALL SQUARE, ROOM 710
BOSTON, MA 02201
(617) 635-4968

GRANITE OR
CONCRETE WEIR (2 OF 2)

DATE OF ISSUE:
DECEMBER 2024

SCALE: N.T.S.

DETAIL NO.

G.402