



SECTION

NOTES:

1. CONCRETE SHALL BE 4000 PSI, AIR ENTRAINED, $\frac{3}{4}$ " MAXIMUM SIZE AGGREGATE. THE CONCRETE SHOULD BE VIBRATED TO ELIMINATE AIR POCKETS.
2. THE FINISHED LEVEL OF THE CONCRETE SURFACE MUST BE APPROX. $\frac{1}{8}$ " ABOVE THE TOP OF THE FRAME.
3. GRATE SHALL HAVE GAPS NO GREATER THAN $\frac{1}{2}$ " WIDE IN ONE DIRECTION. IF GRATE OPENINGS ARE ELONGATED THEN THE LONG DIMENSION SHOULD BE PERPENDICULAR TO THE PRIMARY DIRECTION OF TRAVEL.
4. TRENCH DRAIN SYSTEM SHALL CONFORM TO THE DESIGN LOADING REQUIREMENTS LISTED IN THE SPECIFICATIONS.
5. GRATE SHALL BE ADA COMPLIANT.
6. TRENCH DRAIN SHALL HAVE A MINIMUM 0.5% CONTINUOUS LONGITUDINAL SLOPE ALONG THE BOTTOM OF THE CHANNEL.



**Public Works Department
Engineering Division**

1 CITY HALL SQUARE, ROOM 710
BOSTON, MA 02201
(617) 635-4968

12" TRENCH DRAIN WITH GRATE
CAST-IN-PLACE

DATE OF ISSUE:
DECEMBER 2024

SCALE: N.T.S.

DETAIL NO.

G.106